

TEST CERTIFICATE

Customer Name	Address	Company Name :	Test Instrument Details
Phil Freeman		Alan Freeman	Make/Model : SEAWARD
		Tester Name :	Serial Number : X20-0956
		Alan	

No.	Date	Description	Serial No.	Location	Visual	Polarity	Earth Bond	Class	Insulation	Leakage	Flash	Load KVA	Result	Retest
001	19/07/20	AMP DIST	1		PASS	PASS	PASS 00.10	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
002	19/07/20	IEC	2		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
003	19/07/20	X32	3		PASS	N/A	PASS 00.13	N/A	PASS >99.99	PASS 0.45	N/A 0.00	PASS <0.05	PASS	19/07/2022
004	19/07/20	IEC	4		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
005	19/07/20	AMP	5		PASS	N/A	PASS 00.04	N/A	PASS >99.99	PASS 0.94	N/A 0.00	PASS <0.05	PASS	19/07/2022
006	19/07/20	IEC	6		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
008	19/07/20	ROUTER	7		PASS	N/A	PASS 00.04	N/A	PASS >99.99	PASS 0.16	N/A 0.00	PASS <0.05	PASS	19/07/2022
009	19/07/20	COMMANDO TO POWE	8	I	PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
010	19/07/20	13A TO COMMANDO	9		PASS	PASS	PASS 00.05	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
011	19/07/20	LONG 4 WAY	10		PASS	PASS	PASS 00.20	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
012	19/07/20	LIGHT MULTI BOX	11		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
016	19/07/20	LONG COMMANDO	13		PASS	PASS	PASS 00.22	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
017	19/07/20	LONG COMMANDO	14		PASS	PASS	PASS 00.22	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
018	19/07/20	13A 2 WAY	15		PASS	PASS	PASS 00.16	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
019	19/07/20	POWERCON M-F	16		PASS	PASS	PASS 00.09	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
020	19/07/20	13A IEC COMBI	17		PASS	PASS	PASS 00.25	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
021	19/07/20	13A IEC COMBI	18		PASS	PASS	PASS 00.24	N/A	PASS 86.96	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
022	19/07/20	POWERCON-IEC COM	19		PASS	PASS	PASS 00.04	N/A	PASS 76.37	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
023	19/07/20	POWERCON-IEC COM	20		PASS	PASS	PASS 00.04	N/A	PASS 99.43	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
024	19/07/20	IEC LEAD	21		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022

TEST CERTIFICATE

Customer Name	Address	Company Name :	Test Instrument Details
Phil Freeman		Alan Freeman	Make/Model : SEAWARD
		Tester Name :	Serial Number : X20-0956
		Alan	

No.	Date	Description	Serial No.	Location	Visual	Polarity	Earth Bond	Class	Insulation	Leakage	Flash	Load KVA	Result	Retest
025	19/07/20	IEC-IEC	22		PASS	PASS	PASS 00.13	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
026	19/07/20	IEC	23		PASS	PASS	PASS 00.18	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
027	19/07/20	IEC-IEC	24		PASS	PASS	PASS 00.12	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
028	19/07/20	IEC-IEC	25		PASS	PASS	PASS 00.08	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
029	19/07/20	IEC	26		PASS	PASS	PASS 00.07	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
030	19/07/20	PAR CAN	27		PASS	N/A	PASS 00.11	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/07/2022
031	19/07/20	PAR CAN	28		PASS	N/A	PASS 00.08	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/07/2022
032	19/07/20	COMBI	29		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
033	19/07/20	COMBI	30		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
034	19/07/20	COMBI	31		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
035	19/07/20	COMBI	32		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
036	19/07/20	COMBI	33		PASS	PASS	PASS 00.12	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
037	19/07/20	COMB	34		PASS	PASS	PASS 00.05	N/A	PASS 78.78	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
038	19/07/20	COMBI	35		PASS	PASS	PASS 00.05	N/A	PASS 67.26	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
039	19/07/20	IEC-IEC	36		PASS	PASS	PASS 00.17	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
040	19/07/20	IEC	37		PASS	PASS	PASS 00.07	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
041	19/07/20	13A-POWERCON	38		PASS	PASS	PASS 00.07	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
042	19/07/20	13A-POWERCON	39		PASS	PASS	PASS 00.14	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
043	19/07/20	STAR CLOTH DRIVER	40		PASS	N/A	PASS 00.12	N/A	PASS >99.99	PASS 0.83	N/A 0.00	PASS <0.05	PASS	19/07/2022
044	19/07/20	MOVIG HEAD 3	41		PASS	N/A	PASS 00.10	N/A	PASS >99.99	PASS 0.39	N/A 0.00	PASS <0.05	PASS	19/07/2022

TEST CERTIFICATE

Customer Name	Address	Company Name :	Test Instrument Details
Phil Freeman		Alan Freeman Tester Name :	Make/Model : SEAWARD
		Alan	Serial Number : X20-0956

No.	Date	Description	Serial No.	Location	Visual	Polarity	Earth Bond	Class	Insulation	Leakage	Flash	Load KVA	Result	Retest
045	19/07/20	MOVIG HEAD 4	42		PASS	N/A	PASS 00.11	N/A	PASS >99.99	PASS 0.39	N/A 0.00	PASS <0.05	PASS	19/07/2022
046	19/07/20	MOVING HEAD 2	43		PASS	N/A	PASS 00.12	N/A	PASS >99.99	PASS 0.39	N/A 0.00	PASS <0.05	PASS	19/07/2022
047	19/07/20	MOVIGHEAD 1	44		PASS	N/A	PASS 00.11	N/A	PASS >99.99	PASS 0.41	N/A 0.00	PASS <0.05	PASS	19/07/2022
048	19/07/20	PROJECTOR	45		PASS	N/A	PASS 00.07	N/A	PASS >99.99	PASS 1.29	N/A 0.00	PASS 0.16	PASS	19/07/2022
049	19/07/20	COMMANDO-POWERC	46		PASS	PASS	PASS 00.05	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
050	19/07/20	13A-COMMADO	47		PASS	PASS	PASS 00.06	N/A	PASS 66.62	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
051	19/07/20	COMMANDO M-F	48		PASS	PASS	PASS 00.04	N/A	PASS 73.35	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
052	19/07/20	IEC	49		PASS	PASS	PASS 00.06	N/A	PASS 84.18	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
053	19/07/20	4WAY EXT	50		PASS	PASS	PASS 00.08	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
054	19/07/20	13A-COMMANDO	51		PASS	PASS	PASS 00.04	N/A	PASS 97.51	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
055	19/07/20	COMMANDO M-F	52		PASS	PASS	PASS 00.08	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
056	19/07/20	IEC	53		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
057	19/07/20	PARCAN	54		PASS	N/A	PASS 00.13	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/07/2022
058	19/07/20	PARCAN	55		PASS	N/A	PASS 00.08	N/A	PASS >99.99	PASS 0.12	N/A 0.00	PASS <0.05	PASS	19/07/2022
059	19/07/20	PARCAN	56		PASS	N/A	PASS 00.11	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/07/2022
060	19/07/20	PARCAN	57		PASS	N/A	PASS 00.10	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/07/2022
061	19/07/20	UPLIGH CASE	58		PASS	PASS	PASS 00.24	N/A	PASS 96.42	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/07/2022
062	19/07/20	UPLIGHT 1	59		PASS	N/A	PASS 00.06	N/A	PASS >99.99	PASS 0.17	N/A 0.00	PASS <0.05	PASS	19/07/2022
063	19/07/20	UPLIGHT 2	60		PASS	N/A	PASS 00.14	N/A	PASS >99.99	PASS 0.20	N/A 0.00	PASS <0.05	PASS	19/07/2022
064	19/07/20	UPLIGHT 3	61		PASS	N/A	PASS 00.08	N/A	PASS >99.99	PASS 0.14	N/A 0.00	PASS <0.05	PASS	19/07/2022

TEST CERTIFICATE

Customer Name Phil Freeman	Address	Company Name : Alan Freeman Tester Name : Alan	Test Instrument Details Make/Model : SEAWARD Serial Number : X20-0956
--------------------------------------	----------------	-----------------------------------------------------------------------	--------------------------------------------------------------------------------------------------

No.	Date	Description	Serial No.	Location	Visual	Polarity	Earth Bond	Class	Insulation	Leakage	Flash	Load KVA	Result	Retest
06519/07/20		UPLIGHT 4	62		PASS	N/A	PASS 00.04	N/A	PASS >99.99	PASS 0.20	N/A 0.00	PASS <0.05	PASS	19/07/2022
06619/07/20		UPLIGHT 5	63		PASS	N/A	PASS 00.09	N/A	PASS >99.99	PASS 0.16	N/A 0.00	PASS <0.05	PASS	19/07/2022
06719/07/20		UPLIGHT 6	64		PASS	N/A	PASS 00.19	N/A	PASS >99.99	PASS 0.17	N/A 0.00	PASS <0.05	PASS	19/07/2022
06819/07/20		UPLIGHT 7	65		PASS	N/A	PASS 00.07	N/A	PASS >99.99	PASS 0.12	N/A 0.00	PASS <0.05	PASS	19/07/2022
06919/07/20		UPLIGHT 8	66		PASS	N/A	PASS 00.04	N/A	PASS >99.99	PASS 0.14	N/A 0.00	PASS <0.05	PASS	19/07/2022
07019/07/20		UPLIGHT 9	67		PASS	N/A	PASS 00.04	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/07/2022
07119/07/20		UPLIGHT 10	68		PASS	N/A	PASS 00.08	N/A	PASS >99.99	PASS 0.15	N/A 0.00	PASS <0.05	PASS	19/07/2022