

TEST CERTIFICATE

Customer Name Phil Freeman		Address		Company Name : Alan Freeman				Test Instrument Details Make/Model : SEAWARD Tester Name : Alan Serial Number : X20-0956									
No.	Date	Description	Serial No.	Location	Visual	Polarity	Earth Bond	Class	Insulation	Leakage	Flash	Load KVA	Result	Retest			
00119/08/24		AMP DIST	1		PASS	PASS	PASS 00.10	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
00219/08/24		IEC	2		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
00319/08/24		X32	3		PASS	N/A	PASS 00.13	N/A	PASS >99.99	PASS 0.45	N/A 0.00	PASS <0.05	PASS	19/08/2025			
00419/08/24		IEC	4		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
00519/08/24		AMP	5		PASS	N/A	PASS 00.04	N/A	PASS >99.99	PASS 0.94	N/A 0.00	PASS <0.05	PASS	19/08/2025			
00619/08/24		IEC	6		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
00819/08/24		ROUTER	7		PASS	N/A	PASS 00.04	N/A	PASS >99.99	PASS 0.16	N/A 0.00	PASS <0.05	PASS	19/08/2025			
00919/08/24		COMMANDO TO POWE	8	1	PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
01019/08/24		13A TO COMMANDO	9		PASS	PASS	PASS 00.05	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
01119/08/24		LONG 4 WAY	10		PASS	PASS	PASS 00.20	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
01219/08/24		LIGHT MULTI BOX	11		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
01619/08/24		LONG COMMANDO	13		PASS	PASS	PASS 00.22	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
01719/08/24		LONG COMMANDO	14		PASS	PASS	PASS 00.22	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
01819/08/24		13A 2 WAY	15		PASS	PASS	PASS 00.16	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
01919/08/24		POWERCON M-F	16		PASS	PASS	PASS 00.09	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
02019/08/24		13A IEC COMBI	17		PASS	PASS	PASS 00.25	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
02119/08/24		13A IEC COMBI	18		PASS	PASS	PASS 00.24	N/A	PASS 86.96	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
02219/08/24		POWERCON-IEC COM	19		PASS	PASS	PASS 00.04	N/A	PASS 76.37	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
02319/08/24		POWERCON-IEC COM	20		PASS	PASS	PASS 00.04	N/A	PASS 99.43	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
02419/08/24		IEC LEAD	21		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			

TEST CERTIFICATE

Customer Name Phil Freeman		Address		Company Name : Alan Freeman				Test Instrument Details Make/Model : SEAWARD Tester Name : Alan Serial Number : X20-0956									
No.	Date	Description	Serial No.	Location	Visual	Polarity	Earth Bond	Class	Insulation	Leakage	Flash	Load KVA	Result	Retest			
02519/08/24		IEC-IEC	22		PASS	PASS	PASS 00.13	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
02619/08/24		IEC	23		PASS	PASS	PASS 00.18	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
02719/08/24		IEC-IEC	24		PASS	PASS	PASS 00.12	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
02819/08/24		IEC-IEC	25		PASS	PASS	PASS 00.08	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
02919/08/24		IEC	26		PASS	PASS	PASS 00.07	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
03019/08/24		PAR CAN	27		PASS	N/A	PASS 00.11	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/08/2025			
03119/08/24		PAR CAN	28		PASS	N/A	PASS 00.08	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/08/2025			
03219/08/24		COMBI	29		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
03319/08/24		COMBI	30		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
03419/08/24		COMBI	31		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
03519/08/24		COMBI	32		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
03619/08/24		COMBI	33		PASS	PASS	PASS 00.12	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
03719/08/24		COMB	34		PASS	PASS	PASS 00.05	N/A	PASS 78.78	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
03819/08/24		COMBI	35		PASS	PASS	PASS 00.05	N/A	PASS 67.26	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
03919/08/24		IEC-IEC	36		PASS	PASS	PASS 00.17	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
04019/08/24		IEC	37		PASS	PASS	PASS 00.07	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
04119/08/24		13A-POWERCON	38		PASS	PASS	PASS 00.07	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
04219/08/24		13A-POWERCON	39		PASS	PASS	PASS 00.14	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
04319/08/24		STAR CLOTH DRIVER	40		PASS	N/A	PASS 00.12	N/A	PASS >99.99	PASS 0.83	N/A 0.00	PASS <0.05	PASS	19/08/2025			
04419/08/24		MOVIG HEAD 3	41		PASS	N/A	PASS 00.10	N/A	PASS >99.99	PASS 0.39	N/A 0.00	PASS <0.05	PASS	19/08/2025			

TEST CERTIFICATE

Customer Name Phil Freeman		Address		Company Name : Alan Freeman Tester Name : Alan				Test Instrument Details Make/Model : SEAWARD Serial Number : X20-0956									
No.	Date	Description	Serial No.	Location	Visual	Polarity	Earth Bond	Class	Insulation	Leakage	Flash	Load KVA	Result	Retest			
04519/08/24		MOVIG HEAD 4	42		PASS	N/A	PASS 00.11	N/A	PASS >99.99	PASS 0.39	N/A 0.00	PASS <0.05	PASS	19/08/2025			
04619/08/24		MOVING HEAD 2	43		PASS	N/A	PASS 00.12	N/A	PASS >99.99	PASS 0.39	N/A 0.00	PASS <0.05	PASS	19/08/2025			
04719/08/24		MOVIGHEAD 1	44		PASS	N/A	PASS 00.11	N/A	PASS >99.99	PASS 0.41	N/A 0.00	PASS <0.05	PASS	19/08/2025			
04819/08/24		PROJECTOR	45		PASS	N/A	PASS 00.07	N/A	PASS >99.99	PASS 1.29	N/A 0.00	PASS 0.16	PASS	19/08/2025			
04919/08/24		COMMANDO-POWERC	46		PASS	PASS	PASS 00.05	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
05019/08/24		13A-COMMADO	47		PASS	PASS	PASS 00.06	N/A	PASS 66.62	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
05119/08/24		COMMANDO M-F	48		PASS	PASS	PASS 00.04	N/A	PASS 73.35	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
05219/08/24		IEC	49		PASS	PASS	PASS 00.06	N/A	PASS 84.18	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
05319/08/24		4WAY EXT	50		PASS	PASS	PASS 00.08	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
05419/08/24		13A-COMMANDO	51		PASS	PASS	PASS 00.04	N/A	PASS 97.51	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
05519/08/24		COMMANDO M-F	52		PASS	PASS	PASS 00.08	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
05619/08/24		IEC	53		PASS	PASS	PASS 00.04	N/A	PASS >99.99	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
05719/08/24		PARCAN	54		PASS	N/A	PASS 00.13	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/08/2025			
05819/08/24		PARCAN	55		PASS	N/A	PASS 00.08	N/A	PASS >99.99	PASS 0.12	N/A 0.00	PASS <0.05	PASS	19/08/2025			
05919/08/24		PARCAN	56		PASS	N/A	PASS 00.11	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/08/2025			
06019/08/24		PARCAN	57		PASS	N/A	PASS 00.10	N/A	PASS >99.99	PASS 0.13	N/A 0.00	PASS <0.05	PASS	19/08/2025			
06119/08/24		UPLIGH CASE	58		PASS	PASS	PASS 00.24	N/A	PASS 96.42	N/A 0.00	N/A 0.00	N/A 0.00	PASS	19/08/2025			
06219/08/24		UPLIGHT 1	59		PASS	N/A	PASS 00.06	N/A	PASS >99.99	PASS 0.17	N/A 0.00	PASS <0.05	PASS	19/08/2025			
06319/08/24		UPLIGHT 2	60		PASS	N/A	PASS 00.14	N/A	PASS >99.99	PASS 0.20	N/A 0.00	PASS <0.05	PASS	19/08/2025			
06419/08/24		UPLIGHT 3	61		PASS	N/A	PASS 00.08	N/A	PASS >99.99	PASS 0.14	N/A 0.00	PASS <0.05	PASS	19/08/2025			

[illegible]